

City of Spicer
Mechanical Change-Out / Self-Certification Form

Gas Water Heaters Only

- Is there a shut-off valve on the cold water supply line?
(MN Plumbing Code Section 4715-1800, Subpart 9)*
Yes _____ No _____
- Is the TPR extension within 18 inches of the floor?
(MN Plumbing Code Section 4715.2200, Subpart 4)*
Yes _____ No _____
- Is water heater three (3) inches above floor?
(Uniform Plumbing Code Section 1310.f)*
Yes _____ No _____
- Is water heater six (6) inches from combustible materials?
(Uniform Plumbing Code Section 1308)*
Yes _____ No _____
- Is there working space 30 inches in depth and 36 inches in width in front of the water heater?
(Uniform Plumbing Code Section 1311)*
Yes _____ No _____

Gas Line Hookup / Location - Gas Water Heater and Furnace

- Is there a 1 1/2 drip leg on gas line?
(1991 UMC, Sect. 2212, Subpart C)*
Yes _____ No _____
- Is there a shut-off on the gas line within 36 inches of the heater?
(Uniform Plumbing Code Section 1213.0)*
Yes _____ No _____
- Does the exhaust vent have a positive slope of 1/4 inch per foot?
(Uniform Plumbing code Section 1316.c)*
Yes _____ No _____
- Is unit located other than in a sleeping room, bathroom, toilet room or storage closet? (IRC - G24006.2 - 303.3)*
Yes _____ No _____

I understand the Building Official or his designated Deputy retains the right to inspect this project and to order such changes as may be required to insure Code compliance. I hereby certify that I have performed the gas water heater/gas furnace project at the shown address and have complied with the above listed items.

Name: _____ Permit #: _____

Project Address: _____

Contractor: _____ License #: _____

Contractor Address: _____

Contractor Phone Number: _____

Signature: _____

Date Issued: _____ Date Returned: _____ Date Inspected: _____

This Self-Certification Form is valid for 60 days and must be returned to the City within 60 days of the date issued. Please call Mark Harren at 320-309-6455 for inspections. Or contact City of Spicer at 320-796-5562 with questions.